

I



County of El Paso Purchasing Department
500 East San Antonio, Room 500
El Paso, Texas 79901
(915) 546-2048 / Fax: (915) 546-8180

ADDENDUM 2

To: All Interested Proposers

From: Lucy Balderama, Inventory Bid Technician

Date: June 6, 2008

Subject: RFP # 08-070, (Bid) Parking Curbs for Ascarate Park, Golf Course and Aquatics Department

The Purchasing Department received questions relating to the above referenced proposal; the response to the following question:

1. Are these precast standard wheel stop? Or is there a special design to these?

These are precast standard wheel stops.

2. Are these all to be installed at the same time or over a period of time?

We will install the wheel stops at one time.

3. Is there a special installation requirement?

We want 2 #4 rebar pins for installation.

4. Are the General Requirements such as portable restroom, barricade, installation map, insurance requirements, ect.?

The general requirements are those that are standard to any procurement for El Paso County. We want 400 6foot long precast concrete parking curbs with 2 #4 rebar pins for installation.

-
5. Can you send me specifications of the rods that will attach the new concrete curb to the ground, how deep, how many, material diameter, etc.?

The pins are standard rebar pins non graded-steel #4 reinforced bar commonly used in concrete and masonry structures.