



County of El Paso Purchasing Department
800 E. Overland Room 300
El Paso, Texas 79901
(915) 546-2048 / Fax: (915) 546-8180

ADDENDUM 3

To: All Interested Proposers

From: Linda Gonzalez, Inventory Bid Technician

Date: December 19, 2008

Subject: RFP # 08-169, (RFP) Replacement of the Kitchen, Bakery and Sally Port Sewer Lines for the Detention Facility

The Purchasing Department received the listed questions related to the above referenced proposal:

- 1. We are requesting a copy of your as-built drawing pages. (P-2 and P-3, sewer plumbing diagram)**
Drawings may be reviewed at the office of the facility maintenance section and the contractor may take written notes. However, for security reasons, copies of drawings containing floor plans will not be provided.
- 2. Will there be a place to store our equipment and materials with in the facility?**
Yes, the materials can be placed in bay # 4 and tools and equipment can be placed inside the basement boiler room of the detention facility. As long that the tool and equipment is accounted for daily.
- 3. Also, the location of the foundations (if any) and the slab thickness for the areas where the lines are located?**
The slab thickness is 4" to 6" thick. The foundation (if any) and areas where the lines are located, the drawings may be reviewed at the office of the facility maintenance section.

The Purchasing Department received the listed amendments to the above referenced proposal from the Detention Facility Maintenance Foreman:

1. Amendment to the original specifications.

The sewer lines throughout the basement, Kitchen, Bakery and the Sally Port, shall be replaced up to the basement walls. Vertical sections inside the walls shall not be replaced.

2. Amendment to the original specifications.

The vent lines throughout the basement, Kitchen, Bakery and the Sally Port, embedded inside or below the concrete floor, shall be replaced up to the vertical sections. Vertical sections of the vent pipes shall not be replaced.