



County of El Paso Purchasing Department
800 E. Overland Room 300
El Paso, Texas 79901
(915) 546-2048 / Fax: (915) 546-8180
www.epcounty.com

ADDENDUM 2

To: All Interested Bidders
From: Blanca Carbajal, Procurement Data Analyst
Date: August 24, 2016
Subject: Bid #16-055 Patch Work on Ascencion Road for the County of El Paso

The Purchasing Department has received the following questions:

- 1.) Can the County provide bid documents, project estimate and union requirements?

RESPONSE:

There are no construction drawings for this bid. Contractor shall meet with Owner Rep to identify specific areas once lump sum contract has been awarded. The project site shall be limited to the first 5 miles north of the intersection of Ascencion and Horizon along Ascencion Street. The project will consist of 21 separate locations varying in length but are limited to 12 feet in width (approximate width of single lane). Contractor shall saw cut, remove existing pavement section and replace with new pavement section consisting of 2" of HMAC TxDOT Type C, over 4" of crushed stone base course type A grade 2, over 12" of compacted subgrade.

No owner's estimate will be disseminated at this time.

The contractor shall have a 1 foot over lay onto the existing base to create typical union onto existing pavement section. Field conditions may determine differing circumstances. Contractor shall provide unit pricing for units illustrated on page 7 of bid documents for overrun purposes.